



TRAVANCORE TITANIUM PRODUCTS LIMITED
Kochuveli, Thiruvananthapuram 695 021
Phone : 0471 2502163 email: contract@ttpltd.in

CD/CN/KV-55/ cable removal /20-21

20/10/2020

TENDER NOTICE

"Unwanted cable removal from the campus"

Sealed tenders are invited from experienced firms/ contractors in prescribed format for the work **"Unwanted cable removal from the campus"**. The Tender Form can be had from the office of the undersigned between 9.00 a.m and 3.00 p.m on all working days except Saturdays on remitting the Tender Form cost. The Tender document can also be downloaded from our Website www.travancoretitanium.com and shall submit the Tender along with DD against the Tender Form cost & EMD in favour of Travancore Titanium Products Limited payable at Thiruvananthapuram. The bids will be opened at the date and time given below in the presence of the Tenderers present at that time.

The tender shall be enclosed in an envelope , sealed and superscribed with "Tender No. & date, due date and the name of work. The same shall then be forwarded to the **"Manager (Commercial),ravancore Titanium Products Limited,Kochuveli P.O. Thiruvananthapuram, Kerala, Pin.695 021"**.

Tender Form Cost : Rs.600/- plus GST ie. Total Rs.708/-

Earnest Money Deposit (EMD) : Rs.7500/- (refundable)

(Tender Cost & EMD shall be remitted by DD)

Due date & time :03.11.2020 at 12 Noon

Bid Opening due & time 03.11.2020 at 2 P.M.

For TRAVANCORE TITANIUM PRODUCTS LIMITED


Manager (Commercial)

Encl: Tender Notice & Price Proforma



TRAVANCORE TITANIUM PRODUCTS LIMITED
Kochuveli, Thiruvananthapuram 695 021

Phone : 0471 2502163 FAX: 0471 2501533

CD/CN/KV-55/Cable removal /20-21

20 .10. 2020

TENDER NOTICE

“Unwanted cable removal from the campus”

Due date : 03.11.2020 up to 12 noon (date of submission of tenders)

Sealed tenders are invited from firms/experienced contractors for the work of “Unwanted cable removal from the campus”. The work should be carried out as per the specific instructions contained in the scope of work and terms and conditions given below.

Scope of work:

- 1) All unwanted cables of different sizes laid at different heights inside the plant shall be removed.
 - a. After removal, the existing live cables in the trays shall be tied and secured properly with suitable cable ties/saddles in the trays/walls .
 - b. All cables shall be tested for presents of power / voltage before removal.
- 2) The contractor shall carry suitable equipment for testing the power/ live condition of cables to identify the live cables from a bundle of cables.
- 3) All the dismantled cable shall be measured in meters and tagged and the same shall be moved to the cable yard. The cable tag shall have the following
 1. Date of removal of cable
 2. Size of cable
 3. No: of core of cable
 4. Length of cable in meters
 5. Insulation value in ohms with 1000V insulation tester.
 6. All the above written information shall be kept inside a visible box type plastic enclosure such that , the same shall be protected from water/dust/minor mechanical stress. The enclosure shall be arranged by the contractor.
- 4) The contractor shall ensure that, the work site shall be clean and neat after the completion of work.

Signature of the Bidder

Page 1 of 7

